

## **SPECIFICATIONS FOR VENTING APPROVED GAS BURNING APPLIANCES WITH TYPE “B” GAS VENT PIPE**

The gas vent system shall be so engineered and constructed as to develop a positive flow adequate to exhaust all flue gases to outside atmosphere, without condensation within the vent or spillage at any appliance draft hood.

All flue-gas carrying parts of the vent system shall be Metalbestos® Type B double-wall gas vent piping, and such piping shall be continuous from the appliances' outlets into the Metalbestos® vent top of housing.

Metalbestos® gas vent piping shall be installed in full compliance with the terms of its Underwriters' Laboratories, Inc. Listing, with the manufacturer's installation instructions, and with nationally recognized building codes representing good practice for such installations.